



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

May 3, 2013
Subject: **Trenton**
State WIN: 019340.00
Amendment No.2

Dear Sir/Ms:

Make the following change to the Bid Document:

The following question has been received:

Question: How many 7 ft guardrail posts will be needed?

Response: All new posts will be 7' in length.

Question: How much existing rail is to be removed?

Response: Approximately 200LF

Question: What kind of rail is to be removed?

Response: Type 3B guardrail and four end treatments will be removed from this project.

Consider this change and information prior to submitting your bid on May 8, 2013.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER